

# Agency Information

The certificate is only used for browsing on the web and proves that SETsafe | SETfuse has been certified.

If you need a FULL-VERSION certificate, please contact us: [sales@SETfuse.com](mailto:sales@SETfuse.com)

该证书只用于在网页浏览，证明SETsafe | SETfuse已获得认证，如需要完整版本证书，请联系我们: [sales@SETfuse.com](mailto:sales@SETfuse.com)

# ATTESTATION OF CONFORMITY

Issued to:	Xiamen SET Electronics Co., Ltd. No. 8067 West Xiang'an Road Torch High-Tech Industrial District, Xiang'an 381101 Xiamen, China
For the product:	Surge Protective Devices
Trade name:	SET or SETfuse
Type/Model:	SD10C277XYZ Note: "XYZ" can be AHT, LHT, AH, LH, LH-D or LHT-D.
Ratings:	Test class II / Type 2 & Test class III / Type 3, IP66 Uc = 320 V~, In = 10 kA, I <sub>max</sub> = 25 kA, Uoc = 20 kV, I <sub>accr</sub> = 1,5 kA see further information on Annex
Manufactured by:	Xiamen SET Electronics Co., Ltd. No. 8067 West Xiang'an Road Torch High-Tech Industrial District, Xiang'an 381101 Xiamen, China
Requirements:	EN 61643-11:2012+A11:2018 IEC 61643-11:2011

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 3183404.52 and 3183404.54.

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Shanghai, 26 March 2021

Number: 3183404.05AOC

DEKRA Testing and Certification (Shanghai) Ltd.



Kreny Lin  
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

Page 1 of 2

