

## 认证说明

该证书只用于在网页浏览，证明赛尔特这个型号产品已获得认证。如需完整版

本，请用以下任意一种方式联系获得：

- 邮件： [sales@SETfuse.com](mailto:sales@SETfuse.com)。
- 客服。
- 销售人员。

感谢您对赛尔特的支持！



Product Service

# Attestation of Conformity

No. N8A 107221 0011 Rev. 00

**Model(s):** LFR01-xxA10-yy, LFR01-xxxA10-yy,  
LFR01-450A08-yy

xx=50, 63, 80 and  
xxx=100, 125, 160, 200, 250, 315, 350, 400  
denotes rated current 50A, 63A, 80A, 100A, 125A,  
160A, 200A, 250A, 315A, 350A, 400A respectively.  
yy=BB, FB, BT, FE denotes different terminal type  
BB: Bolt blade terminal  
FB: Flat bolt terminal  
BT: Bolt tag terminal  
FE: Flush end terminal

## Parameters:

Model:	LFR01-xxA10-yy, LFR01-xxxA10-yy	LFR01-450A08-yy
Rated voltage:	DC1000V	DC800V
Rated current:	50A, 63A, 80A, 100A, 125A, 160A, 200A, 250A, 315A, 350A, 400A	450A
Rated breaking capacity:	50kA	
Poles No.:	1-P	
Breaking range and utilization category:	aR	

**Tested according to:** EN 60269-1:2007/A2:2014  
EN 60269-4:2009/A2:2016

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.